

On Nonlinear Systems with Poorly Behaved Zero Dynamics

F. Doyle III F. Allgöwer* S. Oliveira E. Gilles* M. Morari†
 Chemical Engineering 210-41, California Institute of Technology, Pasadena, CA 91125

Abstract

The design of controllers for nonlinear, nonminimum-phase systems is very challenging and is currently considered to be one of the most difficult theoretical control problems. Most control algorithms for nonlinear processes perform a linearization making use of an inverse of the system. In the linear case, the system can be factored into the minimum-phase and the nonminimum-phase parts and only the first one is inverted for purposes of control design. A similar scheme for nonlinear systems is still under investigation.

The present work addresses the problem of synthesizing nonlinear state feedback controllers for nonlinear, nonminimum-phase processes in three different ways. The first approach consists of a partial linearization which preserves stability by using an approximate stable/anti-stable factorization. The second technique can be viewed as an inner-outer factorization based approach. And, finally, in the single-output case, it is shown (through an example) that stabilization of the internal dynamics of a nonminimum-phase system can be achieved by using an additional input if this is feasible in practice. In this case, the manipulated variables have different roles, i.e., one is chosen such as to input/output feedback linearize the system and the second is used to locally stabilize the resulting nonminimum-phase internal dynamics.

1 Introduction

It is widely recognized that a controller must explicitly or implicitly generate a process inverse. Methods with explicit inversion include internal model control [5] and the generalized Smith predictor [11]. When dealing with nonminimum-phase systems, a stable/unstable decomposition is necessary and the controller must invert only the part with stable inverse. These approaches are roughly equivalent (under the assumption of a perfect model) to controlling the corresponding minimum-phase part of the system, leaving the nonminimum-phase component in open-loop.

In the nonlinear case, the problem of constructing control algorithms for processes with unstable inverses is equally important, since the available algorithms also rely either implicitly (see, e.g., [8]) or explicitly (see, e.g., [3]) on generating an inverse of the process. The main difficulty here is that results on decomposition into minimum-phase and nonminimum-phase portions are available only for second-order systems (see [9]).

Recently, Wright and Kravaris ([13]) presented an approach to deal with nonlinear, nonminimum-phase systems based on the notion of statically equivalent outputs; a minimum-phase statically equivalent output is estimated on-line and then an available nonlinear control algorithm is used to control it to the set point. Therefore, instead of looking for a decomposition of the process dynamics, this formulation is based on the calculation of a suitable output function.

One assumption is central in all predictor-type approaches and will also be necessary in this work. The system under consideration is assumed to be open-loop stable.

Throughout the paper, we will consider nonlinear systems affine in the input variables

$$\begin{aligned} \dot{z} &= f(z) + g(z)u, \\ y &= h(z), \quad z \in \mathbb{R}^n, u \in \mathbb{R}^m, y \in \mathbb{R}^p \end{aligned} \quad (1)$$

2 Stable/Anti-stable Factorization Approach

2.1 Motivation

Because controllers resulting from linearization schemes generate an inverse of the process, nonminimum-phase systems do not admit exact input/output linearization with internal stability. However, one can try to linearize as much of the nonlinearities of the system as possible under the constraint that internal stability is preserved. One way of approaching this problem involves an approximate stable/anti-stable factorization of the zero dynamics of the system. This is the technique presented in this section.

2.2 Technique

First system (1) is transformed into normal form (see, e.g., [7]) through a nonlinear change of coordinates ($z_i = \phi_i(x)$, $i = 1, \dots, n$). The resulting system in the transformed variables is then written as:

$$\begin{aligned} \dot{z}_i &= z_{i+1}, \quad i = 1, \dots, r-1 \\ \dot{z}_r &= a(\xi, \eta) + b(\xi, \eta)u \end{aligned}$$

$$\begin{aligned} \dot{\eta} &= c(\xi, \eta) \\ y &= z_1 \end{aligned} \quad (2)$$

where ξ and η are standard notations for the two sets of coordinates, of dimensions r and $n - r$, respectively. Thus

$$\xi = \begin{bmatrix} z_1 \\ \vdots \\ z_r \end{bmatrix} \quad \text{and} \quad \eta = \begin{bmatrix} z_{r+1} \\ \vdots \\ z_n \end{bmatrix}$$

In this form, the $(n - r)$ -dimensional subsystem given by

$$\dot{\eta} = c(\xi, \eta), \quad (3)$$

is completely unobservable and therefore called the internal dynamics of the system. If (3) is locally stable, the standard static control law

$$u = \frac{v - a(\xi, \eta)}{b(\xi, \eta)} \quad (4)$$

linearizes the input/output map of the system with $\frac{y(s)}{z(s)} = H(s)$. However, if the internal dynamics is unstable, this approach does not work because some of the unobservable modes of the system become unstable when linear input/output behavior is imposed. In order to solve this problem, one can try to establish a compromise between making the input/output map "as linear as possible" and some portion of the original internal dynamics observable in order to achieve internal stability. Thus, instead of (4), one can think of using a feedback control law of the form

$$u = \frac{1}{b}(-a - r(\xi, \eta) + v)$$

where $r(\xi, \eta)$ is a general function of the transformed variables chosen such as to eliminate as much of the nonlinearities in the input/output channel as possible under the constraint that the system

$$\begin{aligned} \dot{z}_1 &= z_2 \\ &\vdots \\ \dot{z}_{r-1} &= z_r \\ \dot{z}_r &= -r(\xi, \eta) + v \\ \dot{\eta} &= c(\xi, \eta) \end{aligned} \quad (5)$$

is stabilizable.

An improved way of approaching this problem is to make only the unstable modes of the internal dynamics observable. In order to do this we should first be able to factorize the internal dynamics into stable and anti-stable parts and leave only the stable component unobservable. In general, this factorization cannot be exactly performed. However, an approximate factorization approach can be carried out as follows.

Once we have the system in its normal form, a diffeomorphic transformation

$$T: \begin{cases} \eta_1 = T_1(\eta) \\ \eta_2 = T_2(\eta) \end{cases}$$

is performed, factorizing the undriven internal dynamics (or zero dynamics)

$$\dot{\eta} = c(0, \eta) \triangleq c^*(\eta) \quad (6)$$

into an anti-stable part

$$\dot{\eta}_1 = c_1^*(\eta_1)$$

and a stable part (when viewed as a driven system)

$$\dot{\eta}_2 = c_2^*(\eta_1, \eta_2)$$

where η_1 is the unstable manifold coordinate and η_2 is a coordinate independent of η_1 .

Remark 1: It is not necessary that the transformation T decomposes the system into its anti-stable and stable parts. It is sufficient for stabilization purposes to get the anti-stable part correctly. Therefore, the calculation of T requires only construction of the local stable manifold $W_{loc}^s(0)$.

System (2) with transformation T leads to:

$$\begin{aligned} y &= z_1 \\ \dot{z}_1 &= z_2 \\ \dot{z}_2 &= z_3 \\ &\vdots \\ \dot{z}_{r-1} &= z_r \\ \dot{z}_r &= \bar{a}(\xi, \eta_1, \eta_2) + \bar{b}(\xi, \eta_1, \eta_2)u \\ \dot{\eta}_1 &= c_1(\xi, \eta_1, \eta_2) \end{aligned} \quad (7)$$

*Institut für Systemdynamik & Regelungstechnik, Universität Stuttgart, Germany

†To whom correspondence should be addressed: phone (818)356-4186, fax (818)568-8743, e-mail mm@imc.caltech.edu

$$\eta_2 = c_2(\xi, \eta_1, \eta_2)$$

with

$$c_1(\xi, \eta_1, \eta_2) = \frac{\partial T_1}{\partial \eta} c(\xi, \eta) |_{\eta=T^{-1}(\eta_1, \eta_2)}$$

$$c_2(\xi, \eta_1, \eta_2) = \frac{\partial T_2}{\partial \eta} c(\xi, \eta) |_{\eta=T^{-1}(\eta_1, \eta_2)}$$

Therefore, in order for the stable part to have no influence on the unstable one, the following condition

$$\frac{\partial}{\partial \eta_2} \left(\frac{\partial T_1}{\partial \eta} c(\xi, \eta) |_{\eta=T^{-1}(\eta_1, \eta_2)} \right) = 0$$

must hold everywhere. In general, this will not be the case. However η_2 always enters the expression for η_1 only in terms of order greater than or equal to $q = 2$. This minimal cross-over order is intrinsic to the system and cannot be changed. Therefore, the unstable zero dynamics can be thought of as having a part of order less than q that does not depend on η_2 and higher order terms depending on ξ, η_1, η_2 , i.e.,

$$\eta_1 = c_1(\xi, \eta_1) + \mathcal{O}(\xi^\alpha \eta_1^\beta \eta_2^\gamma)$$

with $\alpha + \beta + \gamma = q$.

The application of the feedback

$$u = \frac{1}{\delta} (-\delta - r(\xi, \eta_1) + v) \quad (8)$$

where $r(\xi, \eta_1)$ is chosen such that the system

$$\begin{aligned} \dot{y} &= z_1 \\ \dot{z}_1 &= z_2 \\ \dot{z}_2 &= z_3 \\ &\vdots \\ \dot{z}_{r-1} &= z_r \\ \dot{z}_r &= -r(\xi, \eta_1) + v \\ \eta_1 &= c_1(\xi, \eta_1) + \mathcal{O}(\xi^\alpha \eta_1^\beta \eta_2^\gamma) \\ \eta_2 &= c_2(\xi, \eta_1, \eta_2) \end{aligned} \quad (9)$$

is stabilizable when terms of order q and higher in the expression for η_1 are neglected.

Thus, if we only consider terms of order up to $q - 1$, the unobservable part of the internal dynamics is stable.

In many cases, the linear approximation can be made stabilizable with a linear feedback term

$$r(\xi, \eta_1) = p^T \xi + s^T \eta_1,$$

s and p being constant vectors of appropriate dimensions, when the linear approximation of the original system is controllable.

Using a nonlinear dependency of r on η_1 and ξ , the remaining nonlinearities in the input/output channel can be influenced. Exact guidelines on how to choose $r(\xi, \eta)$ are however not easy to obtain and there is no guarantee that there will always exist a function $r(\xi, \eta_1)$ such that the system can be stabilized. If no such a $r(\xi, \eta_1)$ exists that renders the resulting system (9) stabilizable, one can also try to make a part of the stable internal dynamics observable in order to achieve stabilizability.

Remark 2: We assumed so far that it is possible to find a transformation to factorize the zero dynamics globally into stable and anti-stable parts. As our accuracy can never exceed order q , it is sufficient for stability to locally decompose the undriven internal dynamics up to order q . This can always be done using similar techniques as in the center manifold theory (see, e.g., [1, 12]). It should however be stressed that, in order to find the exact q , not only a lower bound on the actual q , we need to know the stable/anti-stable transformation. Therefore, this has to be done in an iterative manner.

Remark 3: By using this technique, we get a partially linearized system that is at least locally stable. However, no guarantee can be given that the resulting system is less nonlinear. It is, in general, a nonlinear system of lower order and in many cases the term $r(\xi, \eta)$ can be chosen so as to minimize the effect of nonlinearities in the input/output channel.

2.3 Example

Let us consider the following simple example to motivate the stable/anti-stable factorization approach to the control of nonminimum-phase systems:

$$\begin{aligned} \dot{x}_1 &= x_2 \\ \dot{x}_2 &= -x_1 - 2x_2 + x_3 + 10x_4 + x_3x_4 + u \\ \dot{x}_3 &= -2x_1 - 3x_2 + x_3 \\ \dot{x}_4 &= -x_4 + 0.3x_2^2 \\ y &= x_1 \end{aligned} \quad (10)$$

This is an open-loop stable system with strongly nonlinear input/output behavior and nonminimum-phase properties. This system is already in its normal form and we can easily identify that the last two equations constitute the internal dynamics. Moreover, x_3 is

the unstable mode of the internal dynamics and x_4 the stable one. Note that the stable and the unstable parts of the zero dynamics is already completely decoupled.


By using standard control theory, this system cannot be feedback linearized. However, the following feedback control law:

$$u = x_1 + 2x_2 - x_3 - 10x_4 - x_3x_4 - p_1x_1 - p_2x_2 - s_1x_3 + v$$

exactly linearizes the input/output map and permits the resulting system to achieve internal stability simultaneously. The interesting feature about this simple example is that because the unstable portion of the internal dynamics is linear, it is possible to exactly linearize the input/output map and achieve internal stability at the same time. However, the standard input/output linearization approach is not able to find such a stabilizing control law.

By choosing $p_1 = 3.6, p_2 = 7, s_1 = -4.5$, the closed-loop poles of the linearized system are $\lambda_1 = -1, \lambda_2 = -2, \lambda_3 = -3, \lambda_4 = -1$.

Simulations of the output behavior for the original system and its linearized version for step changes in the input variables (u and v , respectively) are presented below:



3 Inner-Outer Factoration Approach

3.1 Motivation

We have mentioned that exact linear behavior of the input/output map can only be achieved for systems with well-behaved internal dynamics. Thus, the important question to be addressed is the systematic degradation of the linear input/output map in order to achieve stable internal dynamics.

The previous section introduced a stable/anti-stable factorization approach to accomplish this task. In this section, we seek an inner-outer factorization-based approach.

3.2 Technique

The main objective here is, given a nonlinear dynamical system (P) with unstable zero dynamics, to derive a minimum-phase nonlinear system (P_M) with the following properties:

- (i) Poles of the linearization of P around a given equilibrium point = Poles of the linearization of P_M around the same point (along the whole equilibrium manifold),
- (ii) Zeros of the linearization of P around a given equilibrium point = "reflection" of the zeros of the linearization of P_M around the same point (along the whole equilibrium manifold),
- (iii) Static gain of P = Static gain of P_M .

From (ii) we can see immediately that this technique requires all zeros of the linearization of P around the equilibrium point to be in the RHP (i.e., the system has to be maximally nonminimum-phase). This restriction comes from the fact that this approach reflects all the zeros of P when constructing the minimum-phase system P_M .

Here we will not use the normal form of nonlinear systems in the sense of Byrnes/Isidori (2) because, by manipulating $c(\xi, \eta)$ we will not only affect the zero dynamics but also the pole dynamics, which we do not want to disturb since the plant is assumed to be open-loop stable. We will make use of the Fliess canonical form [4] or Zeitz/Krener observability canonical form [14, 10], whose interesting feature is that the pole and zero dynamics manifest themselves separately:

$$\begin{aligned} \dot{z}_1 &= z_2 \\ &\vdots \\ \dot{z}_{n-1} &= z_n \\ \dot{z}_n &= F(z, u, \dot{u}, \dots, u^{(n-r)}) \\ y &= z_1 \end{aligned} \quad (11)$$

In this case, feedback linearization can be achieved by dynamic compensation of the form:

$$F(z, u, \dot{u}, \dots, u^{(n-r)}) = \sum_{i=1}^n \hat{\beta}_i z_i + v \quad (12)$$

where the coefficients $\hat{\beta}_i$ are chosen in the usual way (to achieve desired closed-loop performance).

By performing a Jacobian linearization of the system (11) we obtain:

$$\dot{z}_1 = z_2$$

$$\dot{z}_{n-1} = z_n$$

$$z_n = \alpha_1 z_1 + \alpha_2 z_2 + \dots + \alpha_n z_n + \beta_0 u + \beta_1 \dot{u} + \dots + \beta_{n-r} u^{(n-r)} \quad (13)$$

where

$$\alpha_i = \frac{\partial F}{\partial z_i} \Big|_{e_q},$$

$$\beta_i = \frac{\partial F}{\partial u^{(i)}} \Big|_{e_q},$$

Note that the transfer function for (13) is given by:

$$G^*(s) = \frac{Y(s)}{U(s)} = \frac{\beta_0 + \beta_1 s + \dots + \beta_{n-r} s^{n-r}}{\alpha_1 + \alpha_2 s + \dots + \alpha_n s^n} \quad (14)$$

The construction of the minimum-phase system P_M is performed by application of time reversal to the derivatives of u (a procedure that affects only odd powered derivatives) in order to achieve the "reflection" of the zeros through time $t = 0$. The key point here is that any of the terms appearing in the calculation of the coefficients β_i (which determine the zeros of (14)) will influence the calculation of the coefficients α_i (which determine the pole dynamics of (13)).

To make the idea of time reversal clearer, let us recall the definitions of local stable and unstable manifolds in the neighborhood of a fixed point \bar{x} ($W_{loc}^s(\bar{x}), W_{loc}^u(\bar{x})$):

$$W_{loc}^s(\bar{x}) = \{x \in U \mid \phi_t(x) \rightarrow \bar{x} \text{ as } t \rightarrow \infty; \phi_t(x) \in U \forall t \geq 0\}$$

$$W_{loc}^u(\bar{x}) = \{x \in U \mid \phi_t(x) \rightarrow \bar{x} \text{ as } t \rightarrow -\infty; \phi_t(x) \in U \forall t \leq 0\}$$

where $U \subset \mathbb{R}^n$ is a neighborhood of \bar{x} and $\phi_t(x)$ is the flow of the dynamic system.

Therefore, we notice from these definitions that the spans of the stable and unstable eigenvectors can be "interchanged" by time reversal.

This means that P_M is, by construction, a (locally) minimum-phase system.

The fundamental idea applied to the derivation of P_M is analogous to the inner-outer factorization of linear systems, in which the transfer function of the system (G) is factorized into:

G_M : minimum-phase (invertible) part; unstable zeros of G appear "reflected" through the imaginary axis in G_M .

G_A : stable part; "all-pass"; unity dynamic gain; its poles are equal to the "reflected" zeros of G .

such that, $G = G_M \cdot G_A$.

Thus we can see the "reflection" of the unstable zeros of G across the $j\omega$ -axis to yield poles of G_A and zeros of G_M as a symmetry in time.

The resulting dynamic control law is determined by the solution of the following ordinary differential equation along trajectories of the closed-loop system:

$$F_M(z, u, \dot{u}, \dots, u^{(n-r)}) \doteq$$

$$F(z, u, -\dot{u}, \ddot{u}, -u^{(3)}, \dots, u^{(n-r)}) = \sum_{i=1}^n \hat{\beta}_i z_i + v \quad (15)$$

One of the advantages of the construction of P_M from P is that the calculation is straightforward and, aside from the maximum nonminimum-phase condition on P , no more restrictions are present.

Other important characteristics of this inner-outer factorization procedure are:

- (i) The derivation is in the same spirit as the Hauser approximate linearization approaches (neglecting/adding terms to higher order derivatives of y) [6].
- (ii) The derivation draws on tools from differential algebra which appears to be a more attractive framework for system inversion, realization, etc [4].
- (iii) In terms of complexity of the calculations, the only hurdle is the inversion of the control dependent coordinate transformation. Other approaches for control of nonminimum-phase systems ([13, 9]) involve at least the same level of complexity in the calculation of their so-called "natural coordinates". In particular, [13] also requires the system to be involutive.
- (iv) Although we restrict ourselves to maximally nonminimum-phase systems in this report, the possibility that we could use a stable/anti-stable factorization (the technique described in the previous section) on the differential representation of the plant and then perform the time inversion on the unstable part of the zero dynamics may not be discarded.


Note that this approach provides a minimum-phase portion of the system but does not actually factor P into nonlinear minimum-phase and all-pass components. This is not as critical as it seems, however, because for control design, we are primarily interested in the minimum-phase portion itself.

Since [9] introduces a class of static feedback laws that makes the closed-loop system equivalent, under appropriate coordinate transformations, to a nonlinear first-order all-pass in series with a

linear first-order lag, we found it useful to examine the equivalence between these and our results (in the case of two-dimensional systems). We concluded that the dynamics of the unobservable part of the system in the two cases are not identical (although they can be related by a diffeomorphism and share local stability properties). Kravaris and Daoutidis seek an outer factor that has the same dynamics as the plant and only a different output map. This makes the nonlinear ISE-optimization problem easier. In the present work, the outer factor has dramatically different dynamics (in general, not control affine). This makes the nonlinear ISE-optimization problem somewhat more difficult.

The plant P_M approximates (to some degree) the original nonlinear plant P . Furthermore this "approximation" becomes the outer factor (from inner-outer factorization) in the limit of linear behavior.

This suggests a control architecture like the Smith Predictor for linear plants. The following block diagram illustrates the way the control action, given by solving equation (15) along trajectories of the closed-loop system, is implemented:



Controller C Minimum Phase Correction Signal

Here P_M is the outer factor which has the property that, along the equilibrium locus, it yields an output equivalent to that of P (i.e., they are statically equivalent). Thus, tracking of y is guaranteed by tracking of y_M . The controller, C , is the standard input/output linearizing controller (designed for P_M). We notice that an open-loop observer is required.

3.3 Example

Let us consider a CSTR reactor with isothermic Van de Vusse kinetics and a time delay in the output measurement (approximated with a Padé approximation). Here we will look at a first order Padé approximation, but note that any other approximation is maximally nonminimum-phase as well.

$$\dot{x}_1 = -k_1 x_1 - k_3 x_1^2 + u(x_{10} - x_1)$$

$$\dot{x}_2 = k_1 x_1 - k_2 x_2 + -u x_2$$

$$\dot{x}_3 = \frac{-2}{t_d} x_3 + \frac{4}{t_d} x_2$$

$$y = x_3 - x_2$$

Straightforward calculations lead to:

$$y^{(iii)} = F(x, u, \dot{u}, \ddot{u}) = a(x) + b(x)u + c(x)u^2 + d(x)u^3$$

$$+ e(x)\dot{u} + f(x)u\dot{u} + g(x)\ddot{u} \quad (16)$$

where $x = [x_1, x_2, x_3]^T$.

Therefore, for dynamic feedback linearization, we should synthesize v such that:

$$F(x, u, \dot{u}, \ddot{u}) = -\alpha_1 y - \alpha_2 \dot{y} - \alpha_3 \ddot{y} + kv$$

where the parameters k and $\alpha_i, i = 1, 2, 3$, are designed for closed-loop performance. However, because this is a purely nonminimum-phase system, the above synthesis would lead to an unstable controller. Thus, instead of designing the controller based upon $F(x, u, \dot{u}, \ddot{u})$, we design it based upon $F_M(x, u, \dot{u}, \ddot{u}) \doteq F(x, u, -\dot{u}, \ddot{u})$.

In terms of practical implementation, there is a further complication: we need to construct an open-loop observer in order to reconstruct the state variables (as mentioned before).

So, there are two pieces to the controller design, i.e., generating u (dynamic compensator) and generating the transformed states ($z_i, i = 1, 2, 3$), for the dynamic compensator to use. For the estimator of the states, we employ an open-loop observer requiring u, \dot{u}, \ddot{u} as inputs. Additionally, for the dynamic compensator, we define the following (transformed) F_M function (\hat{F}_M):

$$\hat{F}_M(z, u, \dot{u}, \ddot{u}) = \hat{a}(z, u, \dot{u}) + \hat{b}(z, u, \dot{u})u + \hat{c}(z, u, \dot{u})u^2$$

$$+ \hat{d}(z, u, \dot{u})u^3 + \hat{e}(z, u, \dot{u})\dot{u} + \hat{f}(z, u, \dot{u})u\dot{u} + \hat{g}(z, u, \dot{u})\ddot{u} \quad (17)$$

Then, the resulting dynamical controller (with states u_0, u_1), is given by:

$$\dot{u}_0 = u_1$$

$$\dot{u}_1 = \frac{((- \alpha_1 z_1 - \alpha_2 z_2 - \alpha_3 z_3) + kv)}{\hat{g}}$$

$$- \frac{(\hat{a} + \hat{b}u_0 + \hat{c}u_0^2 + \hat{d}u_0^3 + \hat{e}u_1 + \hat{f}u_0u_1)}{\hat{g}} \quad (18)$$

$$u = u_0$$

4 Multiple-Input Approach

4.1 Motivation

We know that if system (1) has relative degree r at a point x_0 , it is always possible to find a nonlinear coordinate transformation that puts the system in the so-called normal form (in the sense of Byrnes/Isidori) (2). Then it is easy to see that the state feedback

$$u = \frac{v - a(\xi, \eta)}{b(\xi, \eta)}$$

will transform the system into a system whose input/output behavior is identical to that of a linear system having a transfer function

$$\frac{Y(s)}{V(s)} = H(s) = \frac{1}{s^r}$$

As in the normal form $y = z_1$, asymptotic tracking of the output may be achieved by selecting the external input v such that the matrix associated with the first r -dimensional system in (2) has all eigenvalues in the LHP. However, this procedure will work only in the case that the internal dynamics of (2), given by

$$\dot{\eta} = c(\xi, \eta)$$

are locally stable (i.e., in a neighborhood U of the point x_0 , all the eigenvalues of the linearization of $\dot{\eta} = c(0, \eta)$ lie in the LHP).

If the zero dynamics is unstable one can take advantage of additional manipulated variables if available. While some of these variables are used to linearize the input/output map, others may be used to locally stabilize the internal dynamics (which remain unobservable but can now be made stabilizable).

4.2 Technique

To make the explanation clearer, let us consider the single-output case (the extension to MIMO systems is straightforward). Let us suppose that with respect to a certain input u_1 , the system has a well-defined relative degree r at the point x_0 (the operating point around which we desire to operate the system, for example).

Remark: By well-defined relative degree we mean that the point x_0 may not be a singularity. So far, we have identified two different types of singular points, at which the static control law resulting from the input/output linearization procedure described above is not well-defined. In the first case, the gain of the linearization of the system changes sign at the singular point and, in the second, one or more zeros move across the $j\omega$ -axis. In both cases, we lose controllability for all practical purposes.

Let us assume that the obtained zero dynamics is unstable (one or more eigenvalues of its linearization around x_0 has a non-negative real part). If there is another manipulated variable in the real system, then we can consider an extra feedback control law u_2 that will permit us to locally stabilize the zero dynamics. This means that though the zero dynamics is completely undriven with respect to the input u_1 it can have its stability characteristics changed by u_2 .

Of course, this approach is justified only if all the possible manipulated variables with respect to which the system has well-defined relative degree at the operating point of interest, considered separately for purposes of input/output linearization, generate nonminimum-phase zero dynamics.

If we choose u_1 (input with respect to which the system has relative degree r at x_0) to linearize the input/output behavior, we obtain the following "modified" normal form:

$$\begin{aligned} \dot{z}_1 &= z_2 \\ \dot{z}_2 &= z_3 \\ &\vdots \\ \dot{z}_{r-1} &= z_r \\ \dot{z}_r &= a(\xi, \eta, u_2) + b(\xi, \eta, u_2)u_1 \\ \dot{\eta} &= c(\xi, \eta, u_2) \\ y &= z_1 \end{aligned} \quad (19)$$

Then the next step is the selection of $u_2 = u_2(\eta)$, such that the linearization of $\dot{\eta} = c(0, \eta, u_2)$ at x_0 has all eigenvalues in the LHP.

4.3 Example

The example we will consider here is a CSTR reactor with exothermic Van de Vusse kinetics (see [2] for the formulation of the isothermal case):

$$\begin{aligned} A &\stackrel{k_1}{\rightarrow} B \stackrel{k_2}{\rightarrow} C \\ 2A &\stackrel{k_3}{\rightarrow} D \end{aligned}$$

Model for the System:

$$\begin{aligned} \dot{x}_1 &= -k_1(x_3)x_1 - k_3(x_3)x_1^2 + u_1(x_{10} - x_1) \\ \dot{x}_2 &= k_1(x_3)x_1 - k_2(x_3)x_2 - u_1x_2 \\ \dot{x}_3 &= \frac{-\Delta H_1 k_1(x_3)x_1 - \Delta H_2 k_2(x_3)x_2 - \Delta H_3 k_3(x_3)x_1^2}{\rho C_p} \end{aligned}$$

$$+ \frac{u_1(x_{30} - x_3) + \frac{Q}{V}}{\rho C_p} \quad y = x_2 \quad (20)$$

where x_1 and x_2 are the concentrations of A and B , respectively, x_3 is the temperature of the reactor, u_1 is the flow rate (F/V), u_2 is the heat exchanged between the reactor and the surroundings (Q), x_{10} is the concentration of A in the feed stream, x_{30} is the temperature of the feed stream and $k_i(x) = k_{i0}e^{-\frac{E_i}{RT}}$, $i = 1, 2, 3$.

Now let us assume that both the flow rate u_1 and the heat input to the reactor u_2 can be chosen as manipulated variables. We know that linearization of the input/output map can be performed by using a feedback law of the form:

$$u = \frac{1}{L_g L_f^{n-1} h(x)} (-L_f^n h(x) + v)$$

In our system, the relative degree of u_1 is equal to 1 and can be defined on the whole phase plane, since $L_{g_1} h(x) = -x_2 \neq 0$ (where f, g_1, g_2 are defined according to the general format (1)). Therefore the system has well-defined relative degree ($r = 1$) with respect to $u_1 \forall x \in \mathbb{R}^3$. However, if we choose to linearize the input/output behavior of the system by using u_1 , the resulting zero dynamics is nonminimum-phase.

So, let us consider the possibility of using u_2 in order to linearize the input/output map of (20). As

$$K(x) \doteq L_{g_2} L_f h(x) = \frac{1}{V \rho C_p} \frac{\partial}{\partial x_3} [k_1(x_3)x_1 - k_2(x_3)x_2],$$

we conclude that the relative degree of the system with respect to u_2 is not defined everywhere (i.e., $r \neq 2$ at the points for which $K(x) = 0$). This should not be a problem if the operating point we select is not one of the points at which K vanishes identically.

Now suppose it is desired to operate the reactor at the point where B reaches its maximum conversion on the equilibrium curve (which we will call optimum point and denote by x^*), i.e.,

$$\frac{\partial x_2}{\partial x_3}(x^*) = 0$$


Thus we are interested in operating at the point for which the gain between the output $y = x_2$ and x_3 vanishes. Since u_2 is the heat input to the reactor and the gain between the concentration of B (output variable) and the temperature is zero at the optimum, intuition suggests that the use of u_2 to control the system will be problematic.

We can easily show that $K(x^*) \neq 0$, i.e., the gain of the linearization of the system does not vanish at the optimum, which indicates that the singular locus does not intersect the equilibrium manifold at x^* . However, because the only zero of the linearization of the system moves from the LHP to the RHP through infinity, we have controllability problems at this point. Actually, at x^* , the finite zero of the system disappears. Due to this peculiar behavior of the system at x^* , this point is considered to be a singular point.



Note that the kind of singularity that the optimum point represents in this example is different from the singularity that we find in the case of a CSTR reactor with the exothermic kinetics $A \rightleftharpoons B$ (for a more detailed discussion of this example see [3]). In this last case, the gain is zero and simultaneously the zero of the linearization of the system disappears at the optimum point ($K(x^*) = 0$).

Thus, by using u_1 to linearize the input/output behavior we get a nonminimum-phase zero dynamics and by using u_2 for the same purpose we get a not well-defined relative degree at the optimum operating point (which means controllability problems). In order to illustrate the resulting behavior in this last case when we try to make the conversion of B asymptotically approach its maximum value on the equilibrium curve, we have performed some numerical simulations of the system for the given set of parameters: $u_1 = 7$, $\Delta H_1 = -5, \Delta H_2 = -15, \Delta H_3 = -20, E_1 = 15, E_2 = 25, E_3 = 15, k_{10} = 1e8, k_{20} = 1e10, k_{30} = 1e7, x_{10} = 10, x_{30} = 300, \rho C_p = 1, V = 1$. Notice that we have redefined the variables in terms of deviation variables with respect to the coordinates of the optimum point. The external linearizing control variable v was selected such that the matrix associated with the linearization of the system around x^* has one real negative eigenvalue and a pair of complex conjugates with negative real part. Thus the kind of behavior we wish to obtain is that for initial conditions sufficiently close to the origin, the control u_2 is able to drive the system towards the origin.

However, we can clearly see in the plots shown below that despite the huge magnitude of u_2 , the heat removed from the reactor, trajectories starting very close to the origin do not approach the origin and tend to behave in a very unpredictable way.



Thus, as neither one of the inputs, u_1 and u_2 , is satisfactory for linearization of the input/output behavior of the system in the neighborhood of the optimum operating point, we tried to use both of them simultaneously: u_1 for linearization (because the system has a well-defined relative degree equal to 1 with respect to this input), and u_2 for local stabilization of the zero dynamics. The simulation results for the same set of parameters and $u_2^* = -332$ (u_2^* is the value of u_2 at x^*) are shown below. We notice that there exists a considerably large neighborhood of the origin for which the zero dynamics was made asymptotically stable. The operation around the optimum point is feasible in this case and both manipulated variables reach their equilibrium values for all trajectories starting "close" to the origin.



5 Conclusions

As a result of this work some control structures for nonlinear systems with unstable zero dynamics were developed.

The stable/anti-stable factorization approach is an attempt of linearization of as much of the nonlinearities in the input/output map of the system as possible under the constraint that the resulting closed-loop system is stabilizable. Therefore it consists of an approach that establishes a compromise between exact linearization of the input/output behavior and local stabilization of the zero dynamics. Moreover, it seeks an approximate decoupling of the stable and anti-stable parts of the zero dynamics such that the resulting feedback law uses only the first r modes of the normal form, (ξ), and the unstable modes of the zero dynamics, (η_1). This makes the unobservable part of the resulting closed-loop system stable (if one neglects higher order terms).

The inner-outer factorization approach is a very straightforward procedure for the construction of a locally minimum-phase plant P_M from the original plant P by applying time reversal to the derivatives of the manipulated variable u . The resulting control architecture is analogous to the Smith Predictor for linear systems.

Finally, the multiple-input approach is an attempt of local stabilization of the internal dynamics by making use of extra degrees of freedom in the choice of the variables to be manipulated.

References

- [1] C. Byrnes and A. Isidori. Output regulation of nonlinear systems. *IEEE Transactions on Automatic Control*, pages 131-140, 1990.
- [2] J. Van der Vusse. Plug-flow type reactor versus tank reactor. *Chem. Eng. Sci.*, pages 994-997, 1964.
- [3] C. Economou, M. Morari, and O. Palsson. Internal model control. 5.extension to nonlinear systems. *Ind. Engng. Chem. Process Des. Dev.*, page 403, 1986.
- [4] M. Fliess. Generalized controller canonical forms for linear and nonlinear dynamics. *IEEE Transactions on Automatic Control*, pages 994-1001, 1990.
- [5] C. Garcia and M. Morari. Internal model control. 1.a unifying review and some new results. *Ind. Engng. Chem. Process Des. Dev.*, page 308, 1982.
- [6] J. Hauser. Nonlinear control via uniform system approximation. In *Proc. 29th CDC*, 1990.
- [7] A. Isidori. *Nonlinear Control Systems*. Springer-Verlag, 1989.
- [8] C. Kravaris and C. Chung. Nonlinear feedback synthesis by global input/output linearization. *AIChE J.*, page 592, 1987.
- [9] C. Kravaris and P. Daoutidis. Nonlinear state feedback control of second-order nonminimum-phase nonlinear systems. *Computers chem. Engng.*, pages 439-449, 1990.
- [10] A. Krener. Normal forms for linear and nonlinear systems. *Contemp. Math.*, 68, 1987.
- [11] S. Ramanathan, R. Curl, and C. Kravaris. Dynamics and control of quasirational systems. *AIChE J.*, page 1017, 1989.
- [12] S. Wiggins. *Introduction to Applied Nonlinear Dynamical Systems and Chaos*. Springer-Verlag, 1990.
- [13] R. Wright and C. Kravaris. Nonminimum-phase compensation for nonlinear processes. *AIChE J.*, pages 26-40, 1992.
- [14] M. Zeitz. Canonical forms for nonlinear systems. In *IFAC Nonlinear Control Systems Design Proc.*, Capri, 1989.